



City of Denton

City Hall
215 E. McKinney Street
Denton, Texas
www.cityofdenton.com

AGENDA INFORMATION SHEET

DEPARTMENT: Procurement
ACM: Christine Taylor
DATE: July 28, 2025

SUBJECT

Consider recommending adoption of an ordinance of the City of Denton, a Texas home-rule municipal corporation, rejecting any and all competitive proposals under RFP 8717 for the Removal and Safe Disposal of Sodium Hydroxide within the Chlorine Scrubber at the Ray Roberts Water Treatment Plant for Water Production; and providing an effective date (RFP 8717).

INFORMATION/BACKGROUND

The City of Denton conducted a Request for Proposals (RFP) from vendors to remove the contents of a chlorine scrubber, an engineered safety mechanism to remove the danger of chlorine gas in the event of a leak on the two (2) chlorine storage tanks at the Ray Roberts Water Treatment Plant. The chlorine tanks have been emptied on-site as the treatment plant moved to the liquid alternatives for chlorine. Since the chlorine tanks are empty, the safety provided by the presence of the scrubber is no longer warranted and allows for the removal of the sodium hydroxide within the scrubber tank. In an effort to reduce costs, it is recommended to reject these proposals. The requested work will be included in a larger chemical improvement project taking place within the next year.

In accordance with the Local Government Code 252.043, the City Council may reject any and all bids.

RECOMMENDATION

Staff recommends the rejection of all proposals for the Removal and Safe Disposal of Sodium Hydroxide within the Chlorine Scrubber at the Ray Roberts Water Treatment Plant for Water Production.

EXHIBITS

Exhibit 1: Agenda Information Sheet
Exhibit 2: Ordinance

Respectfully submitted:
Lori Hewell, 940-349-7100
Purchasing Manager

For information concerning this acquisition, contact: Daniel Parish, 940-349-7522.

Legal point of contact: Marcella Lunn at 940-349-8333.