

| RFP 6186 - Evaluation Sheet for Supply of Wet Well, Non-Clog Submersible Pumps and Pump Panel for the the City of Denton West Lift Station Project | | | | | | | | | | | | | | | | |
|--|------------------------------------|-----|---|--|-------------------|----------------|-----------------------------------|-----------------------|----------------|-----------------------------------|------------------|----------------|---|---------------------|----------------|---|
| Respondent's Business Name: | | | | | Xylem, Inc.- BAFO | | | Xylem, Inc.- Original | | | Odessa Pumps Inc | | | Pump Solutions, Inc | | |
| Principal Place of Business (City and State) | | | | | Charlotte, NC | | | Charlotte, NC | | | Irving, TX | | | Euless, TX | | |
| Item # | QTY | UOM | Product Description | Description 2 | Unit Price | Extended Price | Estimated Delivery/Completion ARO | Unit Price | Extended Price | Estimated Delivery/Completion ARO | Unit Price | Extended Price | Estimated Delivery/Completion ARO | Unit Price | Extended Price | Estimated Delivery/Completion ARO |
| Section 3A FIBERGLASS WET WELLS; Subsection 02608 | | | | | | | | | | | | | | | | |
| 1 | 1 | EA | Fiberglass Wetwell | As described in Section 3A- Division 2; Site Work/Subsection 02608: Fiberglass Wetwells | \$ 44,500.00 | \$ 44,500.00 | 98 | \$ 76,619.36 | \$ 76,619.36 | 98 | \$ 47,246.00 | \$ 47,246.00 | 56 | \$ 43,065.00 | \$ 43,065.00 | 56 |
| Section 3B NON CLOG DRY SUBMERSIBLE SEWAGE PUMPS; Subsection 11100 | | | | | | | | | | | | | | | | |
| 1 | 2 | EA | Non-Clog Submersible Centrifugal Sewage Pumps System (equivalent to Xylem Flygt NP3202 HT-458, or approved equal) | As described in Section 3B- Division 11-Equipment/ Subsection 11100 Non Clog Submersible Sewage Pumps | \$ 20,999.50 | \$ 41,999.00 | 70 | \$ 20,999.50 | \$ 41,999.00 | 70 | \$ 24,423.00 | \$ 48,846.00 | 84-112 | \$ 25,072.00 | \$ 50,144.00 | 126-154 |
| 2 | 1 | LS | Miscellaneous requirements not described above including | packaging, shipping / delivery | \$ 9,621.22 | \$ 9,621.22 | 70 | \$ 9,621.22 | \$ 9,621.22 | 70 | \$ - | \$ - | Included Above | \$ 7,024.00 | \$ 7,024.00 | 126-154 |
| Section 3C PUMP CONTROL PANELS; Subsection 16310 | | | | | | | | | | | | | | | | |
| 1 | 1 | EA | Lift Station Pump Control Panel | Pump Control Panel to be constructed in accordance with Division 16 - Electrical / Section 16310 - Pump Control Panel and Electrical Drawing Exhibit 4 | \$ 19,687.89 | \$ 19,687.89 | 70 | \$ 19,687.89 | \$ 19,687.89 | 70 | \$ 28,850.00 | \$ 28,850.00 | 28-35 | \$ 24,997.00 | \$ 24,997.00 | 42-56 |
| 2 | 1 | Lot | Spare Parts | As described in Division 16 - Electrical / Section 16310 / Subsection 3.02 | \$ - | \$ - | 70 | \$ - | \$ - | 70 | \$ 715.00 | \$ 715.00 | 28-35 | \$ 2,500.00 | \$ 2,500.00 | 42-56 |
| TOTAL COST OF PRODUCTS | | | | | | \$ 115,808.11 | | | \$ 147,927.47 | | | \$ 125,657.00 | | | \$ 127,730.00 | |
| EVALUATION | | | | | | | | | | | | | | | | |
| 15 | Delivery/ Project Schedule | | | | | 8.6 | 1 | | 8.6 | 1 | | 15.0 | 2 | | 15.0 | 3 |
| 40 | Compliance with Specifications | | | | | 40.0 | | | 40.0 | Vendor quoted pumps as specified | | 20.0 | Vendor bid non compliant pumps | | 20.0 | Vendor bid non compliant pumps |
| 15 | Indicators of probable performance | | | | | 15.0 | | | 15.0 | Vendor quoted pumps as specified | | 15.0 | Non compliant Pumps will lead to increased Life Cycle Costs | | 15.0 | Non compliant Pumps will lead to increased Life Cycle Costs |
| 30 | Price / Total Cost of Ownership | | | | | 30.0 | | | 23.5 | | | 23.1 | | | 22.7 | |
| 100 | TOTAL | | | | | 93.6 | | | 87.1 | | | 73.1 | | | 72.7 | |